Application guide Installation, operating and maintenance manual

AIRCUBE - KSCM/KSHM



• • • Providing indoor climate comfort



Congratulations you have made a wise choice and we feel sure that it will meet your expectations

WARNING: Read this manual before installation, and repair or maintenance work.

CONTENTS	PAGE
. GENERAL DESCRIPTION	2
. DENOMINATION	3
. PRODUCT RANGE UNITS COOLING ONLY	3
. PRODUCT RANGE UNITS HEAT PUMP	3
. PHYSICAL DATA	4
. ELECTRICAL DATA	4
. FAN PERFORMANCES	4
. TECHNICAL DATA	5
. COOLING CAPACITIES	6-7
. HEATING CAPACITIES	8-9
. COOLING PIPING DRAWINGS	10-12
. HEATING PIPING DRAWINGS	13-15
. UNIT DIMENSIONS	16
. UNIT INSTALLATION	17
. PIPE CONNECTIONS	18-20
. ELECTRICAL CONNECTIONS	21
. OPTIONS	22-23
. COMMISSIONING AND OPERATION	24
. MAINTENANCE	25-27

Lennox have been providing environmental solutions since 1895, our range of AIRCUBE continues to meet the standards that have made LENNOX a household name. Flexible design solutions to meet YOUR needs and uncompromising attention to detail. Engineered to last, simple to maintain and Quality that comes as standard. Information on local contacts at www.lennoxeurope.com.

All the technical and technological information contained in this manual, including any drawing and technical descriptions provided by us, remain the property of Lennox and must not be utilised (except in the operation of this product), reproduced, issued to or made available to third parties without the prior written agreement of Lennox.

GENERAL DESCRIPTION

The AIRCUBE range of condensing units, cooling only and heat pump, is of the "air to air" type, and designed for commercial / industrial applications.

They are designed for outdoor installation, with a wide range of options to suit the customer requirements when being matched to other types of indoor units or Air Handling equipment.

CABINET

Made from galvanised steel sheet with an epoxy paint finish, to ensure good weatherproofing and a high resistance to corrosion. (RAL 9002 standard).

The units are constructed with metal base sections to support the weight of the units during handling and transport, and providing a sturdy base for installation.

COMPRESSORS

All units are provided with hermetically sealed compressors, scroll type, cooled by exhaust gas, with internal thermal insulation inside the engine, so no other additional protection is required. The compressor is fitted on vibration mountings both inside and outside.

FANS

The units are supplied with one, two outdoor fans, axial type, of direct coupling and motor with external rotor and excellent features on sound levels.

Two speeds in unit 112D to 214D.

ELECTRICAL PANEL

- Unit wiring in compliance with standard EN 60204-1.
- IP 54 water protection.
- Circuit breaker protection for compressor and fan.
- Compressor and fan working contactors.
- Terminal block and wiring for power supply to the unit.

COOLING & HEATING CIRCUIT

Made of welded dehumidifying copper tube.

The units are supplied with high and low pressure switches, with automatic reset.

Thermostatic expansion valve, 4-way valve, suction receiver and filter drier in heat pump version.

They are supplied charged with Nitrogen.

HEAT EXCHANGERS


Made of copper tubing with aluminum corrugated swirl fins, they are designed and specially dimensioned to obtain the maximum output. Also helping to reduce ice formation, the frequency of defrosting and ensuring maximum operating efficiency of the coil.

CONTROL

- Model: Climatic 40
- Control and check by microprocessor.
- Reading refrigerant temperatures.
- Reading of refrigerant pressure (heat pump units)
- Alarm signaling.
- Diagnostic per circuit.
- Adjustment of parameters adapted for operating conditions
- Hour counter and daily balance of operating time for each compressor by "first in/first out" permutation (units with two compressors).
- Remote alarm signal.
- Fan speed control (22E-86D)

APLICATION	DESCRIPTION
KSCM/KSHM 112D-214D	Available static pressure for outdoor unit up to 125Pa
KSCM/KSHM 112D-214D	Available static pressure for outdoor unit up to 250Pa
KSCM/KSHM 112D-214D with option FP1/FP2	Square frames for adapting discharge air from the unit to a square duct
KSCM/KSHM 112D-214D with option FP1/FP2	Accesories for adapting the condenser air intake to a duct.
KSCM/KSHM 112D-214D with option FP1/FP2	Water defrost collection.
KSCM/KSHM 22E-214D	Electrical box access protection.
KSCM/KSHM 22E-214D	It reduces the peak compressor starting current.
KSCM/KSHM 22E-214D	It assures that unit will not begin operation on detection of overvoltage, tage, phase reversal fault or phase failure.
KSCM/KSHM 22E-214D	It prevents condenser coil against accidental impacts
KSCM/KSHM 22E-214D	Operation of the unit in cooling mode until 0°C. of outdoor temperature. It is a crank case heater for the compressor.
KSCM/KSHM 22E-214D	Operation of the unit in cooling mode until -15°C. of outdoor temperature. It allows refrigerant connection between indoor and outdoor unit until 65m.
KSCM/KSHM 22E-214D	Noise level reduction. It includes compressor jacket.
KSCM 22E-214D	Control of capacity of evaporator by injecting hot gas by-pass.
KSCM/KSHM 22E-214D	They avoid transmission of vibrations to the floor where the unit is installed,
KSCM/KSHM 112D-214D	while unit is operating.
KSCM/KSHM 22E-214D	R-410A refrigerant charge and service valves.
KSCM/KSHM 22E-214D	Liquid and gas service valves to make easier maintenance operations.
KSCM/KSHM 22E-214D	It includes the contactor and thermal switch, for indoor motor.
	·
KSCM/KSHM 22E-214D	BMS as communications protocoll.
KSCM/KSHM 22E-214D	Protection from aggressive external environmetal conditions of outdoor coil.
	KSCM/KSHM 112D-214D KSCM/KSHM 112D-214D KSCM/KSHM 112D-214D KSCM/KSHM 112D-214D with option FP1/FP2 KSCM/KSHM 22E-214D KSCM/KSHM 12D-214D KSCM/KSHM 112D-214D KSCM/KSHM 22E-214D

OUTDOOR UNIT



PRODUCT RANGE UNITS COOLING ONLY WITH REFRIGERANT R-410A



OUTDOOR UNIT	Ph/V/Hz	NOMINAL (*) CAPACITY kW COOLING	NOMINAL (*) CONSUMPTION KW COOLING		
KSCM 22E	3N~400V 50Hz	19.7	6.43		
KSCM 26E	3N~400V 50Hz	24.7	8.10		
KSCM 32E	3N~400V 50Hz	28.4	9.63		
KSCM 38E	3N~400V 50Hz	36.1	11.9		
KSCM 43E	3N~400V 50Hz	42.0	14.1		
KSCM 52D	3N~400V 50Hz	49.4	16.2		
KSCM 64D	3N~400V 50Hz	56.7	19.3		

OUTDOOR UNIT	Ph/V/Hz	NOMINAL (*) CAPACITY kW COOLING	NOMINAL (*) CONSUMPTION KW COOLING		
KSCM 76D	3N~400V 50Hz	72.1	23.7		
KSCM 86D	3N~400V 50Hz	83.9	28.3		
KSCM 112D	3N~400V 50Hz	104	34.3		
KSCM 128D	3N~400V 50Hz	115	37.1		
KSCM 152D	3N~400V 50Hz	141	46.2		
KSCM 214D	3N~400V 50Hz	197	63.4		

^(*) Evaporating temperature= +7°C / Ambient, temperature=+35°C DB/24°C WB.

PRODUCT RANGE UNITS HEAT PUMP WITH REFRIGERANT R-410A



OUTDOOR	Ph/V/Hz	NOM CAPAC		NOM CONSUMI	INAL PTION kW
UNIT		COOLING (*)	H. PUMP (**)	COOLING (*)	H. PUMP (**)
KSHM 22E	3N~400V 50Hz	19.7	19.8	6.43	6.18
KSHM 26E	3N~400V 50Hz	24.7	25.0	8.10	7.78
KSHM 32E	3N~400V 50Hz	28.4	28.6	9.63	9.18
KSHM 38E	3N~400V 50Hz	36.1	36.0	11.9	11.1
KSHM 43E	3N~400V 50Hz	42.0	40.2	14.1	12.9
KSHM 52D	3N~400V 50Hz	49.4	50.1	16.2	15.6
KSHM 64D	3N~400V 50Hz	56.7	57.1	19.3	18.4

OUTDOOR	Ph/V/Hz	NOM CAPAC		NOMINAL CONSUMPTION KW			
UNIT		COOLING (*)	H. PUMP (**)	COOLING (*)	H. PUMP (**)		
KSHM 76D	3N~400V 50Hz	72.1	71.9	23.7	22.2		
KSHM 86D	3N~400V 50Hz	83.9	80.3	28.3	25.9		
KSHM 112D	3N~400V 50Hz	104	105	34.3	32.4		
KSHM 128D	3N~400V 50Hz	115	114	37.1	35.6		
KSHM 152D	3N~400V 50Hz	141	137	46.2	43.8		
KSHM 214D	3N~400V 50Hz	197	191	63.4	59.8		

- (*) Evaporating temperature= +7°C / Ambient temperature=+35°C DB.
- (**) Condensing temperature 50°C/Ambient temperature 6°C WB.

DB: Dry bulb WB: Wet bulb

PHYSICAL DATA

22E

26E-43E

52D-86D









MODELS I	KSCM/KSH	IM	22E	26E	32E	38E	43E	52D	64D	76D	86D	112D	128D	152D	214D
Compresso	r	Nr / Type		1 / Scroll			2 / Scroll				3 / Scroll			4/Scroll	
• " "		Nr		1					2			3			4
Capacity st	eps	%			0-100%				0-50-	100%		0-60-	100%	0-50-	100%
Not weight	KSCM	kg	160	210	216	233	255	443	452	481	520	632	797	906	1659
Net weight	KSHM	kg	168	219	221	239	258	452	463	499	537	748	828	932	1684
Dimensions	3														
Height		mm	1375	1375	1375	1375	1375	1375	1375	1375	1375	1875	1875	1875	1975
Width		mm	660	980	980	980	980	1195	1195	1195	1195	1420	1420	1420	2300
Length		mm	1195	1195	1195	1195	1195	1960	1960	1960	1960	2250	2250	2250	2250
Refrigerant	connection	s													
Liquid			1/2"	5/8"	5/8"	5/8"	5/8"	2x(5/8")	2x(5/8")	2x(5/8")	2x(5/8")	3/4"+5/8"	3/4"+5/8"	2x(3/4")	2x(7/8")
Gas			7/8"	1 1/8"	1 1/8"	1 3/8"	1 3/8"	2x(1 1/8")	2x(1 1/8")	2x(1 3/8")	2x(1 3/8")	1 5/8"+1 3/8"	1 5/8"+1 3/8"	2x(1 5/8")	2x(1 5/8")

ELECTRICAL DATA

MODELS KSCM/KSHM		22E	26E	32E	38E	43E	52D	64D	76D	86D	112D	128D	152D	214D
Voltage	Ph/V/Hz		3N~400V-50Hz											
Max. absorbed power	kW	8.55	10.8	12.5	16.4	17.7	21.6	25.0	32.8	35.5	45.6	48.7	59.9	83.0
Maximum current	Α	16.6	24.0	25.4	29.0	34.4	48.0	50.8	58.0	68.8	84.0	90.4	110	152
Start up current	Α	87.5	97.4	103.7	137.7	171.7	121.4	129	167	206	221	228	292	454

MODELS KSCM/KSHM V FP1/FP2 OPTION	WITH	112D FP1/FP2	128D FP1/FP2	152D FP1/FP2	214D FP1/FP2
Voltage	Ph/V/Hz		3N~400	V-50Hz	
Max. absorbed power	kW	47.6/51.8	50.6/54.8	60.9/65.1	88.8/97.2
Maximum current	Α	87.2/93.8	93.6/100	111/118	161.2/174.4
Start up current	Α	225/231	231/238	294/300	463.7/477

VOLTAGE OPERATING LIMITS: 342-462V

FAN PERFORMANCES

MODELS KSCM/KS	МН		22E	26E	32E	38E	43E	52D	64D	76D	86D	112D	128D	152D	214D
		Type		Condenser fan helicoidal											
Fan type		Ph/V/Hz		1~230V-50Hz				3~400V-50Hz							
C	C1+C2	r.p.m.	900	900	900	900	900	900+900	900+900	900+900	900+900	900+700	900+700	900+900	900+900
Fan number			2					2			2				4
Air flow C	C1+C2	m³/h	6800	9750	11500	11300	11000	9750+ 9750	11500+ 11500	11300+ 11300	11000+ 11000	22700+ 18100	22700+ 18100	22700+ 22700	28600+ 28600

MODELS KSCM/KSF FP1/FP2 OPTION	IM WITH	112D FP1/FP2	128D FP1/FP2	152D FP1/FP2	214D FP1/FP2			
	Туре	Condenser high static fan						
Fan type	Ph/V/Hz		3~400V-50Hz					
	r.p.m.		900 FP1 (Low speed) /	1450 FP2 (High speed)				
Fan number			2		4			

Air flow data. FP1 option.

Air flow data. FP2 option.

MODE	LS:			112D-128D-152D	214D			
Fan type	:		Axial "short case"-direct coupling 900 r.p.m.(Low speed) 3~400V					
Fan num	ber:			2 4				
0	50	0 50	Air flow	m ³ /h	19000+19000	28000+28000		
a ∰	50	Absorbed power	kW	5	10			
먑	75	Air flow	m ³ /h	18000+18000	24000+24000			
<u>e</u> e	75	Absorbed power	kW	5.1	10.2			
de S	100	Air flow	m ³ /h	17000+17000	22000+22000			
es ≘ë	100	Absorbed power	kW	5.2	10.4			
Available static pressure Pa.	125	Air flow	m ³ /h	15000+15000	20000+20000			
4	123	Absorbed power	kW	5.3	10.6			

MODE	LS:			112D-128D-152D	214D		
Fan type	:			Axial "short case 1450 r.p.m. (High	e" direct coupling n speed) 3~400V		
Fan num	ber:			2 4			
.ల .	150	Air flow	m³/h	22000+22000	34000+34000		
Pa	130	Absorbed power	kW	9.2	18.4		
s e s	200	Air flow	m³/h	20000+20000	28000+28000		
lab	200	Absorbed power	kW	9.3	18.6		
4 Absorbed power 200 Absorbed power Absorbed power		m³/h	18000+18000	24000+24000			
Absorbed power kW				9.4	18.8		

TECHNICAL DATA











214D

SOUND PRESSURE / SOUND POWER LEVELS FOR OUTDOOR UNIT

140011				SP	ECTRUM F	PER OCTAN	/E BAND (dB)		Sound power	Sound pressure at 10 m
KSCM/	KSHM		125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	Lw dB(A)	Lp dB(A)
22E	(1)		68	71	71	71	69	67	59	76	48
225	(2)		68	71	71	71	68	65	58	75	47
26E	(1)		74	70	72	70	73	70	62	78	50
201	(2)		74	70	70	66	72	67	62	76	48
32E	(1))	80	72	74	75	76	71	65	81	53
022	(2)		80	72	73	74	74	66	65	79	51
38E	(1)		80	72	74	75	75	69	62	80	52
	(2)		80	72	73	74	73	65	62	79	51
43E	(1)	- 1	80	72	74	76	76	68	63	81	53
	(2)	-	80	72	73	74	74	65	63	79	51
52D	(1)		77	73	75	73	76	73	65	81	53
<u> </u>	(2)	-	77	73	73	69	75	70	65	79	51
64D	(1)	- 1	83	75	77	78	79	74	68	84	56
	(2)		83	75	76	77	77	69	68	82	54
76D	(1)		83	75	77	78	78	72	65	83	55
	(2)	-	83	75	76	77	76	68	65	82	54
86D	(1)	- 1	83	75	77	79	79	71	66	84	56
	(2)	-	83	75 71	76 75	77 78	77 77	68 71	66 65	82 82	54 54
	Low speed	(1)	73	71	75 72			63	65		50
112D	<u> </u>	(2)	73 82	71	79	75 83	71 82	76	67	78 87	59
	High speed	(1) (2)	82	78	79 78	82	81	74	67	86	58
	Low	(1)	73	71	75	78	78	72	66	83	55
	speed	(2)	73	71	72	75 75	72	63	66	79	51
128D	High	(1)	82	78	79	83	82	76	68	87	59
	speed	(2)	82	78	78	82	81	74	68	86	58
	Low	(1)	75	73	77	82	84	77	69	87	59
152D	speed	(2)	75	73	74	77	76	66	69	81	53
1325	High	(1)	84	81	81	85	86	80	71	90	62
	speed	(2)	84	81	80	84	84	77	71	88	60
	Low	(1)	76	75	78	82	84	76	66	88	60
214D	speed	(2)	74	71	73	76	76	65	66	81	53
	High	(1)	79	77	80	84	85	76	67	89	61
	speed	(2)	79	77	78	81	81	68	67	85	57
	112D	(1)	84	81	81	84	81	74	68	87	59
	1120	(2)	84	81	80	84	80	72	68	87	59
	128D	(1)	84	81	80	84	82	75	69	88	60
FP1	.202	(2)	84	81	80	84	80	72	69	87	59
OPTION	152D	(1)	84	81	81	85	85	78	71	90	62
		(2)	84	81	80	84	81	72	71	87	59
	214D	(1)	87	84	84	88	86	78	71	91	63
		(2)	87	84	83	87	83	75	71	90	62
	112D	(1)	96	94	92	93	89	86	82	97	69
		(2)	96	94	92	93	89	86	82	97	69
	128D	(1)	96	94	92	93	90	86	82	97	69
FP2 OPTION		(2)	96	94	92	93	89	86	82	97	69
OFTION	152D	(1)	96	94	92	93	90	87	82	97	69
		(2)	96	94	92	93	89	86	82	97	69
	214D	(1)	99	97	95	96	93	89	85	100	72
		(2)	99	97	95	96	92	89	85	100	72

- (1) The above data shows noise levels without compressor isolation (option).
- (2) The above data shows noise levels with compressor isolation.

For units: KSCM/KSHM 112D to 214D

- Low speed: For ambient temperatures < +35°C and unit working on cooling mode.
 - For ambient temperatures > +7°C and unit working on heating mode.
- High speed: For ambient temperatures ≥+35°C and unit working on cooling mode.
 - For ambient temperatures ≤ +7°C and unit working on heating mode.
- Global sound power level measured in compliance with ISO standard 3744 and under Eurovent certification program.
- Sound pressure in dB(A) calculated at 10 m, in a free field on a reflecting surface, is given as a guide only and with a directibility of +/- 3 dBA.
- Only the sound power spectrum and the global sound power value are used in determining pressure characteristics on site. Remark for FP1/FP2 option:

Total Lw, is global sound power level radiated for the fan motor AT FREE DISCHARGE. Sound pressure level (Lp) has to be calculated according the pressure drop introduce in the installation considering the type of the air duct, isolation class, duct length, etc ...

This value is orientative and must always consider for each installation the value of sound power level in the table to calculate the vaue of sound presure level.

COOLING CAPACITIES R-410A

MODELS KSCM 22E 26E

EVAPORATING	kW	AIR ENTI		RATURE IN °C (DRY B		UTDOOR	AIR ENTRY TEMPERATURE INTO THE OUTDOOR UNIT °C (DRY BULB)					
TEMPERATURE	IXVV	25°C	30°C	35°C	40°C	45°C	25°C	30°C	35°C	40°C	45°C	
0°C	Total Capacity	17.3	16.8	15.9	14.7	13.5	21.9	21.3	20.0	18.5	16.8	
0.0	Power Input	5.27	5.55	6.01	6.67	7.42	6.71	7.01	7.64	8.46	9.41	
5°C	Total Capacity	20.3	19.8	18.6	17.2	15.8	25.6	24.9	23.3	21.6	19.8	
9°C	Power Input	5.49	5.71	6.30	6.97	7.73	6.95	7.25	7.95	8.78	9.73	
7°C	Total Capacity	21.6	21.0	19.7	18.3	16.8	27.2	26.4	24.7	22.9	21.0	
1-0	Power Input	5.59	5.84	6.43	7.10	7.86	7.05	7.39	8.10	8.93	9.88	
10°C	Total Capacity	24.0	23.0	21.5	20.0	18.4	30.1	28.6	26.8	24.9	22.9	
10-0	Power Input	5.64	6.03	6.64	7.31	8.08	7.11	7.64	8.35	9.18	10.1	
4.500	Total Capacity	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	
15°C	Power Input	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	

32E 38E

EVAPORATING	kW	AIR ENTRY TEMPERATURE INTO THE OUTDOOR UNIT °C (DRY BULB)					AIR ENTRY TEMPERATURE INTO THE OUTDOOR UNIT °C (DRY BULB)					
TEMPERATURE	1000	25°C	30°C	35°C	40°C	45°C	25°C	30°C	35°C	40°C	45°C	
0°C	Total Capacity	25.4	24.7	23.0	21.1	19.1	32.0	31.4	29.4	27.3	25.0	
0-0	Power Input	7.94	8.25	9.11	10.1	11.2	9.83	10.2	11.2	12.3	13.5	
5°C	Total Capacity	29.7	28.8	26.8	24.6	22.4	37.5	36.4	34.1	31.6	29.0	
3 0	Power Input	8.20	8.60	9.48	10.5	11.6	10.1	10.6	11.7	12.8	14.1	
7°C	Total Capacity	31.8	30.5	28.4	26.1	23.8	40.1	38.5	36.1	33.5	30.7	
7 0	Power Input	8.21	8.76	9.63	10.6	11.7	10.1	10.8	11.9	13.0	14.3	
10°C	Total Capacity	35.2	33.1	30.8	28.4	25.9	44.2	41.8	39.1	36.3	33.3	
10 0	Power Input	8.24	9.01	9.90	10.9	12.0	10.2	11.2	12.2	13.4	14.7	
15°C	Total Capacity	n/a	n/a	n/a	n/a	n/a	50.4	47.5	44.5	41.2	37.8	
19 C	Power Input	n/a	n/a	n/a	n/a	n/a	10.8	11.8	12.8	14.0	15.3	

43E 52D

EVAPORATING	kW	AIR ENT		RATURE IN °C (DRY B		UTDOOR	AIR ENTRY TEMPERATURE INTO THE OUTDOOR UNIT °C (DRY BULB)					
TEMPERATURE	17.4.4	25°C	30°C	35°C	40°C	45°C	25°C	30°C	35°C	40°C	45°C	
0°C	Total Capacity	37.5	36.6	34.3	31.8	29.1	43.8	42.5	40.0	37.0	33.7	
0.0	Power Input	11.6	12.0	13.2	14.5	16.0	13.4	14.0	15.3	16.9	18.8	
5°C	Total Capacity	44.3	42.4	39.7	36.8	33.7	51.2	49.8	46.6	43.2	39.6	
9°C	Power Input	11.8	12.6	13.9	15.2	16.7	13.9	14.5	15.9	17.6	19.5	
7°C	Total Capacity	47.4	44.9	42.0	38.9	35.7	54.5	52.7	49.4	45.8	42.0	
1-0	Power Input	11.8	12.9	14.1	15.5	17.0	14.1	14.8	16.2	17.9	19.8	
10°C	Total Capacity	51.6	48.6	45.5	42.2	38.6	60.2	57.2	53.6	49.8	45.7	
10-0	Power Input	12.2	13.3	14.6	16.0	17.5	14.2	15.3	16.7	18.4	20.3	
4.500	Total Capacity	58.6	55.2	51.6	47.7	n/a	n/a	n/a	n/a	n/a	n/a	
	Power Input	12.9	14.1	15.4	16.8	n/a	n/a	n/a	n/a	n/a	n/a	

64D 76D

EVAPORATING	kW	AIR ENTE		RATURE IN °C (DRY B		UTDOOR	UNIT °C (DRY BULB)					
TEMPERATURE	1000	25°C	30°C	35°C	40°C	45°C	25°C	30°C	35°C	40°C	45°C	
0°C	Total Capacity	50.8	49.4	45.9	42.2	38.2	64.1	62.7	58.7	54.5	50.0	
0-0	Power Input	15.9	16.5	18.2	20.2	22.4	19.7	20.3	22.3	24.5	26.9	
5°C	Total Capacity	59.5	57.5	53.5	49.3	44.8	75.0	72.8	68.2	63.3	58.1	
3 0	Power Input	16.4	17.2	19.0	20.9	23.2	20.3	21.2	23.3	25.6	28.1	
7°C	Total Capacity	63.7	60.9	56.7	52.3	47.5	80.3	77.0	72.1	66.9	61.4	
7 0	Power Input	16.4	17.5	19.3	21.2	23.5	20.3	21.7	23.7	26.1	28.6	
10°C	Total Capacity	70.4	66.2	61.6	56.9	51.8	88.5	83.5	78.3	72.6	66.6	
10 0	Power Input	16.5	18.0	19.8	21.8	24.0	20.5	22.3	24.4	26.8	29.3	
15°C	Total Capacity	n/a	n/a	n/a	n/a	n/a	101	95.0	88.9	82.4	75.5	
13 0	Power Input	n/a	n/a	n/a	n/a	n/a	21.7	23.6	25.7	28.1	30.7	

86D 112D

EVAPORATING	kW	AIR ENTE		RATURE IN °C (DRY B		UTDOOR	AIR ENTRY TEMPERATURE INTO THE OUTDOOR UNIT °C (DRY BULB)					
TEMPERATURE	11.4.4	25°C	30°C	35°C	40°C	45°C	25°C	30°C	35°C	40°C	45°C	
0°C	Total Capacity	74.9	73.3	68.6	63.6	58.3	92.0	89.1	84.1	78.0	71.5	
0-0	Power Input	23.3	24.1	26.5	29.1	31.9	28.4	29.8	32.3	35.5	39.1	
5°C	Total Capacity	88.6	84.9	79.4	73.6	67.5	108	104	97.7	90.7	83.3	
3 0	Power Input	23.6	25.3	27.7	30.5	33.4	29.1	30.7	33.7	37.0	40.6	
7°C	Total Capacity	94.8	89.7	83.9	77.8	71.3	115	110	104	96.1	88.2	
7 0	Power Input	23.7	25.8	28.3	31.0	34.0	29.3	31.3	34.3	37.6	41.3	
10°C	Total Capacity	103.2	97.3	90.9	84.3	77.2	126	120	112	104	95.8	
10 0	Power Input	24.3	26.6	29.1	31.9	35.0	30.1	32.3	35.3	38.6	42.4	
15°C	Total Capacity	117	110	103	95.5	n/a	n/a	n/a	n/a	n/a	n/a	
13 0	Power Input	25.9	28.1	30.7	33.5	n/a	n/a	n/a	n/a	n/a	n/a	

n/a: Not available

COOLING CAPACITIES

MODELS KSCM 128D 152D

EVAPORATING	kW	AIR ENT		RATURE IN		UTDOOR	AIR ENTRY TEMPERATURE INTO THE OUTDOOR UNIT °C (DRY BULB)				
TEMPERATURE	IX V	25°C	30°C	35°C	40°C	45°C	25°C	30°C	35°C	40°C	45°C
0°C	Total Capacity	102	99.0	93.4	86.6	79.3	125	122	115	106	97.1
0.0	Power Input	30.8	32.2	35.0	38.5	42.4	38.5	39.8	43.5	47.8	52.5
5°C	Total Capacity	119	116	109	101	92.5	146.6	142.5	133.1	123.4	113
3 0	Power Input	31.8	33.2	36.4	40.1	44.1	39.1	41.5	45.4	49.7	54.6
7°C	Total Capacity	127	123	115	107	97.9	157	151	141	131	120
7-0	Power Input	32.0	33.8	37.1	40.7	44.8	40.1	42.3	46.2	50.6	55.5
10°C	Total Capacity	140	133	125	116	106	174	164	153	142	130
10 C	Power Input	32.3	34.8	38.1	41.8	45.9	40.3	43.6	47.6	52.0	56.9
15°C	Total Capacity	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
19-0	Power Input	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

214D

n/a: Not available

EVAPORATING	kW	AIR ENTE		RATURE IN °C (DRY B	ITO THE O	UTDOOR
TEMPERATURE	IXVV	25°C	30°C	35°C	40°C	45°C
0°C	Total Capacity	174	170	160	148	136
0.0	Power Input	52.7	54.6	59.4	65.3	72.0
5°C	Total Capacity	204	199	186	173	159
9-0	Power Input	54.7	56.7	62.1	68.3	75.3
7°C	Total Capacity	218	211	197	183	168
7 6	Power Input	55.1	57.9	63.4	69.6	76.6
10°C	Total Capacity	241	229	214	199	183
10 C	Power Input	55.5	59.8	65.3	71.7	78.9
15°C	Total Capacity	277	261	244	227	210
150	Power Input	58.3	63.3	69.0	75.5	83.0

CAPACITY PARTIALITY

KSCM/KSHM	22E	26E a 43E	52D a 86D	112D	128D	152D	214D
Capacity steps %	0-100	0-100	0-55-100	0-35-59-100	0-38-62-100	0-30-50-100	0-28-50-78-100

CORRECTION FACTORS COOLING MODE

To find out the performances for units installed with air ducts, apply the following coefficients for capacity and consumption, over the performance tables of standard fan units without ducts.

_	NITS NG ONLY	VERSION	MODELS	Available static pressure Pa	Maximum ambient temperature °C	Correction coeffcient cooling capacity	Correction coeffcient consumption ((1) only FP1/FP2)
ပ	50Pa	STANDARD	22E-214D	30	43	0.95	1.06
AIR AVAILABLE STATIC PRESSURE UP TO	SUPa	STANDARD	22E-214D	50	39	0.89	1.16
լ ը.				50	45	0.964	1.072
	125Pa	FP1	112D-214D	75	42	0.935	1.094
88	12354	FFI	1120-2140	100	38	0.9	1.171
∃ੋਂਂ				125	36	0.856	1.269
∣≱ü				150	47	1.01	0.98
\ \fr	250Pa	FP2	112D-214D	200	44	0.97	1.037
₹				250	41	0.94	1.099

(1) After applying correction coefficient consumption is needed to add the following power input to get total power consumption.

	EXTRA POWER COMSUPTION										
MODELS 112D 128D 152D 214D											
FP1	1.95	1.95	1	5.8							
FP2	6.25	6.25	5.3	14 4							

OPERATING LIMITS FOR (COOLING ONLY) UNITS

		MAXIMUM TEMPERATURES	MINIMUM TEMPERATURES
	INDOOR TEMPERATURE	32°C DB / 23°C WB	21°C DB / 15°C WB
COOLING CYCLE OPERATION	OUTDOOR TEMPERATURE	45°C (22E-26E-32E-52D-64D) 47°C (38E-43E-76D-86D-112D- 128D-152D-214D)	+10°C STANDARD UNIT 0°C (*) -15°C (**)

DB.- Dry bulb temperature. WB.- Wet bulb temperature.

^(*) With kit low temperature 0°C option.

^(**) With kit low temperature -15°C option.

HEATING CAPACITIES R-410A

MODELS KSHM	22E	26E
CONDENSING	 AIR ENTRY TEMPERATURE INTO THE OUTDOOR	AIR ENTRY TEMPERATURE IN

CONDE	K///	AIR	ENTRY	TEMPER UNIT °	ATURE I C (WET		E OUTD	OOR	AIR	ENTRY ⁻		ATURE I C (WET	NTO THE BULB)	OUTDO	OOR
TEMPER	ATURE	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	12.9	15.0	17.4	20.0	21.1	22.4	29.9	16.5	19.0	22.0	25.3	26.7	28.3	37.8
30 C	Power Input	3.89	3.92	3.95	3.98	3.99	4.01	4.15	5.22	5.22	5.21	5.20	5.19	5.20	5.29
35°C	Total Capacity	12.9	14.8	17.1	19.6	20.8	22.0	29.2	16.3	18.8	21.7	24.9	26.3	27.9	37.0
33 C	Power Input	4.36	4.38	4.41	4.43	4.45	4.46	4.58	5.77	5.76	5.74	5.73	5.73	5.73	5.84
40°C	Total Capacity	12.8	14.7	16.9	19.3	20.4	21.6	28.6	16.2	18.7	21.5	24.5	25.9	27.4	36.1
40 0	Power Input	4.88	4.90	4.92	4.94	4.96	4.97	5.07	6.41	6.38	6.35	6.32	6.32	6.32	6.41
45°C	Total Capacity	n/a	14.6	16.7	19.0	20.1	21.2	27.9	n/a	18.5	21.2	24.1	25.5	26.9	35.2
73 0	Power Input	n/a	5.49	5.51	5.52	5.53	5.54	5.61	n/a	7.11	7.05	7.01	6.99	6.98	7.06
50°C	Total Capacity	n/a	n/a	16.6	18.8	19.8	20.9	27.3	n/a	n/a	20.9	23.8	25.0	26.4	34.4
30 C	Power Input	n/a	n/a	6.17	6.18	6.18	6.19	6.24	n/a	n/a	7.88	7.80	7.78	7.76	7.79
55°C	Total Capacity	n/a	n/a	n/a	18.6	19.5	20.5	26.6	n/a	n/a	n/a	23.4	24.6	25.9	33.5
33 C	Power Input	n/a	n/a	n/a	6.93	6.93	6.93	6.95	n/a	n/a	n/a	8.74	8.70	8.67	8.63

32E 38E

CONDE	K ///	AIR	ENTRY	TEMPER UNIT °	ATURE I C (WET		E OUTD(OOR	AIR	ENTRY	TEMPER UNIT °	ATURE I C (WET		OUTDO	OOR
TEMPER	ATURE	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	18.9	21.8	25.2	28.9	30.5	32.3	42.7	23.9	27.4	31.5	36.0	37.9	40.0	53.1
30 C	Power Input	6.01	6.01	6.00	5.99	5.99	6.00	6.11	7.41	7.46	7.49	7.51	7.52	7.55	7.84
35°C	Total Capacity	18.7	21.5	24.8	28.4	30.0	31.8	41.9	23.7	27.2	31.2	35.5	37.4	39.5	52.1
35 C	Power Input	6.70	6.69	6.67	6.65	6.65	6.65	6.71	8.10	8.19	8.24	8.25	8.26	8.27	8.45
40°C	Total Capacity	18.5	21.3	24.5	28.0	29.5	31.2	41.0	23.5	27.0	30.9	35.1	37.0	39.0	51.2
40 0	Power Input	7.46	7.45	7.42	7.39	7.38	7.37	7.39	8.85	8.99	9.07	9.10	9.10	9.11	9.20
45°C	Total Capacity	n/a	21.1	24.2	27.5	29.0	30.7	40.1	23.4	26.7	30.5	34.7	36.5	38.5	50.2
45 C	Power Input	n/a	8.32	8.28	8.24	8.22	8.20	8.17	9.65	9.86	9.98	10.0	10.1	10.1	10.1
50°C	Total Capacity	n/a	n/a	23.9	27.1	28.6	30.1	39.1	23.2	26.5	30.2	34.2	36.0	37.9	49.1
30 C	Power Input	n/a	n/a	9.26	9.20	9.18	9.15	9.07	10.5	10.8	11.0	11.1	11.1	11.1	11.2
55°C	Total Capacity	n/a	n/a	n/a	26.7	28.1	29.6	38.1	23.0	26.3	29.9	33.8	35.4	37.3	48.0
33 C	Power Input	n/a	n/a	n/a	10.3	10.3	10.2	10.1	11.4	11.8	12.1	12.2	12.3	12.3	12.4

43E 52D

CONDE	K///	AIR	ENTRY T	TEMPER UNIT °	ATURE C		E OUTD	OOR	AIR	ENTRY	TEMPER UNIT °	ATURE I C (WET		OUTD	OOR
TEMPER	ATURE	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	26.5	30.4	34.9	39.8	42.0	44.3	58.7	32.9	38.0	44.0	50.5	53.4	56.7	75.7
30°C	Power Input	8.54	8.64	8.68	8.70	8.71	8.73	8.99	10.4	10.4	10.4	10.4	10.4	10.4	10.6
35°C	Total Capacity	26.3	30.2	34.6	39.4	41.5	43.7	57.7	32.7	37.7	43.4	49.8	52.6	55.7	73.9
35 C	Power Input	9.34	9.48	9.56	9.59	9.59	9.60	9.74	11.5	11.5	11.5	11.5	11.5	11.5	11.7
40°C	Total Capacity	26.2	30.0	34.3	39.0	41.0	43.2	56.7	32.4	37.3	42.9	49.0	51.7	54.7	72.2
40 C	Power Input	10.2	10.4	10.5	10.6	10.6	10.6	10.7	12.8	12.8	12.7	12.7	12.7	12.7	12.8
45°C	Total Capacity	16.1	29.8	34.0	38.6	40.6	42.7	55.7	n/a	36.9	42.4	48.3	50.9	53.8	70.5
45 C	Power Input	11.1	11.4	11.6	11.7	11.7	11.7	11.8	n/a	14.2	14.1	14.0	14.0	14.0	14.1
50°C	Total Capacity	25.9	29.6	33.8	38.2	40.2	42.2	54.7	n/a	n/a	41.8	47.5	50.1	52.8	68.7
30 C	Power Input	12.1	12.5	12.8	12.9	12.9	13.0	13.0	n/a	n/a	15.8	15.6	15.6	15.5	15.6
55°C	Total Capacity	25.8	29.5	33.5	37.8	39.7	41.7	53.7	n/a	n/a	n/a	46.8	49.3	51.9	67.0
35 C	Power Input	13.2	13.7	14.0	14.2	14.3	14.4	14.4	n/a	n/a	n/a	17.5	17.4	17.3	17.3

64D 76D

	AIR ENTRY TEMPERATURE INTO THE OUTDO							OR AIR ENTRY TEMPERATURE INTO THE OUTDOOR							
CONDE	NSING LAA	AIR	ENTRY T		ATURE I		E OUTD	OOR	AIR	ENTRY		ATURE I		E OUTD	OOR
TEMPER	ATURE kW	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	37.7	43.6	50.4	57.8	61.0	64.6	85.4	47.9	54.9	63.0	71.9	75.8	80.1	106
30 C	Power Input	12.0	12.0	12.0	12.0	12.0	12.0	12.2	14.8	14.9	15.0	15.0	15.1	15.1	15.7
35°C	Total Capacity	37.3	43.1	49.7	56.9	60.0	63.6	83.8	47.5	54.4	62.3	71.0	74.9	79.0	104
35 C	Power Input	13.4	13.4	13.3	13.3	13.3	13.3	13.4	16.2	16.4	16.5	16.5	16.5	16.5	16.9
40°C	Total Capacity	37.0	42.6	49.0	56.0	59.0	62.5	82.1	47.1	53.9	61.7	70.2	73.9	78.0	102
40 C	Power Input	14.9	14.9	14.9	14.8	14.8	14.8	14.8	17.7	18.0	18.1	18.2	18.2	18.2	18.4
45°C	Total Capacity	n/a	42.2	48.4	55.1	58.1	61.4	80.2	46.7	53.5	61.1	69.3	72.9	76.9	100
45 C	Power Input	n/a	16.6	16.6	16.5	16.4	16.4	16.3	19.3	19.7	20.0	20.1	20.1	20.1	20.2
50°C	Total Capacity	n/a	n/a	47.8	54.2	57.1	60.2	78.3	46.3	53.0	60.4	68.4	71.9	75.8	98.2
30 C	Power Input	n/a	n/a	18.5	18.4	18.4	18.3	18.1	21.0	21.6	22.0	22.2	22.2	22.2	22.3
55°C	Total Capacity	n/a	n/a	n/a	53.5	56.2	59.1	76.3	46.0	52.5	59.8	67.5	70.9	74.6	96.1
35 C	Power Input	n/a	n/a	n/a	20.6	20.5	20.5	20.2	22.9	23.7	24.2	24.5	24.6	24.6	24.7

86D 112D

CONDE	K///	AIR	ENTRY	TEMPER UNIT °	ATURE I C (WET		E OUTD	OOR	AIR	ENTRY		ATURE I C (WET		OUTDO	OOR
TEMPER	ATURE	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	53.0	60.8	69.7	79.6	84.0	88.5	117	69.4	79.8	91.9	105	111	117	156
30 C	Power Input	17.1	17.3	17.4	17.4	17.4	17.5	18.0	28.8	21.9	22.0	22.0	22.0	22.1	22.9
35°C	Total Capacity	52.7	60.4	69.1	78.8	83.0	87.4	115	68.8	79.1	90.8	104	109	116	153
35 C	Power Input	18.7	19.0	19.1	19.2	19.2	19.2	19.5	23.9	24.1	24.1	24.1	24.1	24.2	24.7
40°C	Total Capacity	52.4	60.0	68.6	78.0	82.1	86.4	113	68.2	78.3	89.8	102	108	114	150
40 0	Power Input	20.4	20.8	21.1	21.2	21.2	21.2	21.3	26.2	23.5	26.6	26.6	26.6	26.6	26.9
45°C	Total Capacity	52.1	59.6	68.0	77.2	81.2	85.4	111	n/a	77.5	88.7	101	106	112	146
45 0	Power Input	22.2	22.8	23.2	23.4	23.4	23.4	23.5	n/a	29.1	29.3	29.3	29.3	29.3	29.5
50°C	Total Capacity	51.9	59.3	67.6	76.5	80.3	84.4	109	n/a	n/a	87.6	99.4	105	110	143
30 0	Power Input	24.2	25.0	25.5	25.8	25.9	25.9	26.0	n/a	n/a	32.3	32.4	32.4	32.4	32.5
55°C	Total Capacity	51.7	59.0	67.1	75.7	79.4	83.5	107	n/a	n/a	n/a	97.9	103	108	140
33 C	Power Input	26.3	27.3	28.0	28.5	28.6	28.7	28.9	n/a	n/a	n/a	35.9	35.9	36.0	36.0

HEATING CAPACITIES

MODELS KSHM

128D 152D

CONDE	- · · k \/\/	AIR	ENTRY	TEMPER UNIT °	ATURE I C (WET		E OUTD	OOR	AIR	ENTRY ⁻	TEMPER UNIT °	ATURE I C (WET		E OUTD	OOR
TEMPER	RATURE	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C	-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	75.8	87.2	100	115	121	128	170	90.7	104	120	138	146	154	205
30-0	Power Input	23.6	23.8	23.8	23.9	23.9	24.0	24.9	29.3	29.6	29.7	29.9	30.0	30.1	30.9
35°C	Total Capacity	75.1	86.3	99.1	113	119	126	167	90.1	103	119	136	143	152	201
35-0	Power Input	26.0	26.2	26.3	26.3	26.3	26.3	26.9	32.2	32.4	32.6	32.7	32.8	32.9	33.5
40°C	Total Capacity	74.5	85.5	98.0	112	118	124	163	89.7	103	118	134	141	149	197
40°C	Power Input	28.5	28.8	29.0	29.0	29.0	29.0	29.3	35.4	35.7	35.8	36.0	36.0	36.1	36.5
45°C	Total Capacity	n/a	84.7	96.9	110	116	122	160	n/a	102.0	116	132	139	147	192
45 C	Power Input	n/a	31.8	32.0	32.1	32.1	32.1	32.2	n/a	39.3	39.5	39.6	39.7	39.7	40.0
50°C	Total Capacity	n/a	n/a	95.8	109	114	120	156	n/a	n/a	115	131	137	145	188
30 C	Power Input	n/a	n/a	35.4	35.5	35.6	35.6	35.6	n/a	n/a	43.6	43.8	43.8	43.8	44.0
55°C	Total Capacity	n/a	n/a	n/a	107	112	118	153	n/a	n/a	n/a	129	135	142	184
35 C	Power Input	n/a	n/a	n/a	39.4	39.4	39.5	39.4	n/a	n/a	n/a	48.5	48.5	48.5	48.7

214D

CONDEN	ν····· ν·			UNIT	ATURE I	BULB)		
TEIVII ETG		-11°C	-6°C	-1°C	4°C	6°C	8°C	18°C
30°C	Total Capacity	126	145	167	191	202	213	284
30 C	Power Input	40.0	40.3	40.6	40.9	41.0	41.2	42.4
35°C	Total Capacity	125	143	165	188	199	210	279
35-0	Power Input	43.7	44.1	44.4	44.7	44.8	44.9	45.9
40°C	Total Capacity	124	142	163	186	196	207	273
40 C	Power Input	47.9	48.4	48.7	49.0	49.1	49.2	50.0
45°C	Total Capacity	n/a	142	162	184	193	204	267
45°C	Power Input	n/a	53.2	53.6	54.0	54.1	54.2	54.9
50°C	Total Capacity	n/a	n/a	161	181.7	191	201	262
50°C	Power Input	n/a	n/a	59.3	59.7	59.8	59.9	60.5
55°C	Total Capacity	n/a	n/a	n/a	180	189	198	256
99°C	Power Input	n/a	n/a	n/a	66.2	66.3	66.4	67.0

n/a: Not available

CAPACITY PARTIALITY

KSCM/KSHM	22E	26E a 43E	52D a 86D	112D	128D	152D	214D
Capacity steps %	0-100	0-100	0-55-100	0-35-59-100	0-38-62-100	0-30-50-100	0-28-50-78-100

CORRECTION FACTORS HEATING MODE

To find out the performances for units installed with air ducts, apply the following coefficients for capacity and consumption, over the performance tables of standard fan units without ducts.

H Pi	NITS EAT UMP	VERSION	MODELS	Available static pressure Pa	Maximum ambient temperature °C	Correction coeffcient heating capacity	Correction coeffcient consumption ((1) only FP1/FP2)
E STATIC UP TO	50Pa	STANDARD	22E-214D	30	-9	0.94	1.02
₹2	SUFa	STANDARD	22E-214D	50	-8	0.89	1.03
ເນ <u>¬</u>				50	-10	1	1
ABLE JRE U	125Pa	FP1	112D-214D	75	-8	0.94	1.02
유론	125Fa	FFI		100	-6	0.89	1.03
<u> </u>				125	-5	0.87	1.04
AVAILABL RESSURE				150	-10	1.01	0.99
Z Z	₹ E 250Pa	FP2	112D-214D	200	-10	1	1
AR P				250	-8	0.94	1.02

(1) After applying correction coefficient consumption is needed to add the following power input to get total power consumption.


	EXTRA	POWER COMS	UPTION									
MODELS 112D 128D 152D 214D												
FP1	1.95	1.95	1	5.8								
FP2	6.25	6.25	5.3	14.4								

OPERATING LIMITS FOR (HEAT PUMP) UNITS


		MAXIMUM TEMPERATURE	MINIMUM TEMPERATURE
	INDOOR TEMPERATURE	32°C DB / 23°C WB	21°C DB / 15°C WB
COOLING CYCLE OPERATION	OUTDOOR TEMPERATURE	45°C (22E-26E-32E-52D-64D) 47°C (38E-43E-76D-86D-112D- 128D-152D-214D)	0°C
	INDOOR TEMPERATURE	27°C DB	15°C DB
HEATING CYCLE OPERATION	OUTDOOR TEMPERATURE	DEPENDING ON MODELS (See tables for heating capacities)	-10°C DB / -11°C WB

DB.- Dry bulb temperature WB.- Wet bulb temperature

COOLING PIPING DRAWINGS




OUTDOOR UNIT





Pressure gauge. (5/16" to use by the installer). Low pressure switch, circuit 1. Low pressure switch, circuit 2. High pressure switch, circuit 1. High pressure switch, circuit 2. Crank case heater. (Low ambient 0°C option). Crank case heater. (Low ambient 0°C option). Pressure transducer, circuit 1. (Low ambient -15°C). PT1 Pressure transducer, circuit 2. (Low ambient -15°C). Condensing temperature sensor, circuit 1. TS1 Condensing temperature sensor, circuit 2.

TS2


COOLING PIPING DRAWINGS










COOLING PIPING DRAWINGS







HEATING PIPING DRAWINGS




---- OPTIONAL ELEMENT

LP1 LP2 HP1 HP2 Low pressure switch, circuit 1. Low pressure switch, circuit 2. High pressure switch, circuit 1. High pressure switch, circuit 2. Crank case heater. CH2 Crank case heater. Crank case heater. PT1 Pressure transducer, circuit 1. Pressure transducer, circuit 2.

Pressure gauge. (5/16" to use by the installer).

HEATING PIPING DRAWINGS



Pressure gauge. (5/16" to use by the installer).
Low pressure switch, circuit 1.
Low pressure switch, circuit 2.

High pressure switch, circuit 1.
High pressure switch, circuit 2.

Condensing pressure control low/high speed, circuit 1.

Condensing pressure control low/high speed, circuit 2.

Crank case heater.


CH2 Crank case heater.

Crank case heater.

PT1 Pressure transducer, circuit 1.

PT2 Pressure transducer, circuit 2.

HEATING PIPING DRAWINGS



Pressure gauge. (5/16" to use by the installer).

Low pressure switch, circuit 1.

Low pressure switch, circuit 2.

High pressure switch, circuit 1.

High pressure switch, circuit 2.

Condensing pressure septral law/high speed si

Condensing pressure control low/high speed, circuit 1.
Condensing pressure control low/high speed, circuit 2.

Crank case heater.

CH2 Crank case heater.

Снз Crank case heater.

Crank case heater.

Pressure transducer, circuit 1.

PT2 Pressure transducer, circuit 2.


UNIT DIMENSIONS

MODELS KSCM/KSHM 26E-32E-38E-43E Main switch 22E (optional) Main switch (optional) Electrical Electrical box box Power supply Power supply 1195 980 660 Access to gas Access to gas and liquid lines and liquid lines 112D-128D-152D 52D-64D-76D-86D Main switch Electrical box Main switch (optional) (optional) Electrical box 1 1375 1875 1960 Access to gas and liquid lines 1195 1420 Power supply Access to gas Access to gas and liquid lines and liquid lines Power supply 214D Main switch (optional) Electrical box 975 Access to gas and liquid lines 2300 Power supply Access to gas and liquid lines


NOTE: As an option, service valves are available for liquid and gas lines with welded connection.

UNIT INSTALLATION


MOUNTING PLATES




26E-32E-38E-43E




52D-64D-76D-86D



112D-128D-152D






Sizes in mm.

DETAILING SPRING ANTI-VIBRATION POSITION KSCM/KSHM


112D-128D-152D



POSITION Nr.	ANTIVIBRATION TYPE
1	350
2	350
3	350
4	350

4	350
5	350
6	350
7	250
8	250
9	250

214D




POSITION Nr.	ANTIVIBRATION TYPE
1	350
2	500
3	500
4	500
5	500
6	500
7	500
8	350
9	350
10	350
11	350
12	350


SERVICE SPACE

22E


Space should be left free for access and servicing, and for intake and discharge air flow as well.








52D-64D-76D-86D=1m 112D-128D-152D ()=1.5m



214D



PIPE CONNECTIONS

REFRIGERANT CONNECTIONS

Refrigerant connections on outdoor unit

NOTE: The unit is supplied with welded connections.

As an option, service valves are available for liquid and gas lines with welded connection.

As an option, refrigerant factory precharged kit is available (this option includes service valves).

SEE OPTION SECTION IN THIS MANUAL (pg. 22)



Piping connection lines


For calculating piping connection lines between outdoor and indoor units, distance and drop between lines are very important aspects.

To achieve the best features for the units, take special care about:

- The gas line must be always insulated.
- The horizontal lines must be sloped at least 2% toward the outdoor unit .
- The minimum speed suction must not be below 6 m/s on the vertical line of the gas line, and siphons must be installed every few meters upward to assure the oil returns to the compressor properly.
- The maximum speed inside lines should not be higher than 15m/s.

RECOMMENDATIONS FOR REFRIGERANT LINES CONNECTIONS

To locate the outdoor and the indoor units, refer to the following recommendations



POSITION A: A siphon suction must be installed on the vertical line of the gas line, and siphons must be installed every 8 meters upward. The minimum speed suction must not be below 6m/s. Maximum vertical length 16m. POSITION B: Tip the lines toward the outdoor unit. Make special attention to line length longer than 10m, and avoid collapse on pipe lines installation.

POSITION C: Install a siphon at the base of the vertical of the gas line, no more siphons are necessary. Maximum vertical length 6m.

TABLE 1: REFRIGERANT LINES SELECTION

DEE	REFRIGERANT LINES				UNIT - MODEL											
KEFI	RIGERAN	I LINES		22E	26E	32E	38E	43E	52D	64D	76D	86D	112D	128D	152D	214D
		(X Liquid	C1	1/2"	5/8"	5/8"	5/8"	5/8"	5/8"	5/8"	5/8"	5/8"	3/4"	3/4"	3/4"	7/8"
Length	0 to 30 m.	Ø Liquid	C2	n/a	n/a	n/a	n/a	n/a	5/8"	5/8"	5/8"	5/8"	5/8"	5/8"	3/4"	7/8"
between indoor and	(Standard connection	~ • • • • • • • • • • • • • • • • • • •	C1	7/8"	1 1/8"	1 1/8"	1 3/8"	1 3/8"	1 1/8"	1 1/8"	1 3/8"	1 3/8"	1 5/8"	1 5/8"	1 5/8"	1 5/8"
outdoor unit.	of unit)	Ø Gas	C2	n/a	n/a	n/a	n/a	n/a	1 1/8"	1 1/8"	1 3/8"	1 3/8"	1 3/8"	1 3/8"	1 5/8"	1 5/8"
outdoor unit.	or armity	Max. Nr. of b	ends	6	12	8	18	12	12	8	18	12	12	12	12	12"

Maximum refrigerant piping length: 30m

PIPE CONNECTIONS



The units are factory pre-charged with Nitrogen (N_2) . The installer should remove this gas and charge the units with refrigerant R-410A.

Amount of refrigerant charge R-410A for the installation

The amount of refrigerant R-410A for the system will depend on the size of connecting line between indoor and outdoor unit and on the expansion system of the indoor unit. Prior to charging the unit, a proper vacuum must be done. Finally, it is necessary to adjust the expansion system, with the unit already charged, to achieve the best features for the units, such as evaporating temperature, condensing temperature, discharge, etc.



PRECAUTIONS TO BE TAKEN IN THE USE OF R-410A Refrigerant:

R-410A Refrigerant is used in the unit; therefore, the following precautions characteristic of this gas should be taken:

- The Vacuum Pump must have a Check Valve or Solenoid Valve.
- Pressure Gauges and Hoses for the exclusive use with R-410A Refrigerant should be used.
- The charge should be carried out in the Liquid Phase.
- Always use scales to weight-in charge
- Use the Leak Detector exclusive for R-410A Refrigerant.
- Do not use mineral oil, only synthetic oil to ream, expand or make connections.
- Keep pipes wrapped before using them and be very thorough about any possible dirt (dust, filings, burrs, etc.).
- When there is a leak, gather what is left of the charge, create a vacuum in the unit and completely recharge with new R-410A Refrigerant.
- Brazing should always be carried out in a nitrogen atmosphere.
- Reamers should always be well sharpened.

TABLE 2: RECOMMENDATIONS FOR WEIGHT OF REFRIGERANT R-410A PER METER OF LINE

Liquid	Gas	gr/m
1/2"	7/8"	108
5/8"	1 1/8"	177
5/8"	1 3/8"	182
3/4"	1 3/8"	265
3/4"	1 5/8"	271
7/8"	1 5/8"	374

TABLE 3: RECOMMENDATIONS FOR CHARGE OF REFRIGERANT

	Charge of refrigerant (gr) R-410A for 0 meters of line KNCM+indoor unit (Cooling only)												
	22E	26E	32E	38E	43E	52D	64D	76D	86D	112D	128D	152D	214D
C1	4655	5315	5700	7950	9745	6250	5775	7870	9800	12130	15585	15500	23100
C2						6250	5775	7870	9800	10450	10045	15400	23100

	Charge of refrigerant (gr) R-410A for 0 meters of line KNHM + indoor unit (Heat pump)												
	22E	26E	32E	38E	43E	52D	64D	76D	86D	112D	128D	152D	214D
C1	4900	5900	6330	8835	10830	6940	6420	8740	10900	13480	17315	17230	25660
C2						6940	6420	8740	10900	11600	11160	17100	25660

PIPE CONNECTIONS

CHARGE OF REFRIGERANT FOR THE SET:

EXAMPLE:

To install a KNHM 32E + indoor unit, with 22m refrigerant line length between outdoor and indoor unit, then the refrigerant charge must be calculated as follow:


- 1.-TABLE 1 (pg.18), for 22m of line length between indoor unit and outdoor unit, the line sizes are: liquid 5/8" and gas 1 1/8".
- 2.-TABLE 2 (pg.19), for line sizes of 5/8"-1 1/8", the charge per meter line is: 177 gr/m x 22m = 3894 gr.
- 3.-TABLE 3 (pg.19), charge of refrigerant for the set with 0m of line length is: 6330 gr.
- 4.-To determine the carge of the set:


Add charge of the refrigerant lines + charge of refrigerant indoor unit and outdoor unit.

Total charge for the set: 3894 + 6330 = 10224 gr

Note: If the outdoor unit includes factory pre-charged kit, only take care of weight of refrigerant per meter of line in TABLE 2.

112D to 152D units with 3 compressors are working using three capacity steps and 214D with 4 capacity steps. See the picture below for the installation in the case of units with tandem compressor circuit. An additional gas line has to be used to assure the correct operation of the system.





- 2 Coupled trap.
- 3 Lower trap with double tubes.
- 4 Higher trap with double tubes.

Models with tandem compressor


112D	128D	152D	214D
Circuit 1	Circuit 1	Circuit 1	Circuits 1 & 2

ELECTRICAL CONNECTIONS




- BEFORE MAKING ANY ELECTRICAL CONNECTIONS, BE SURE THAT ALL CIRCUIT BREAKES ARE OPEN.
- IN ORDER TO CARRY OUT ELECTRICAL CONNECTIONS, FOLLOW THE ELECTRICAL DIAGRAM SUPPLIED WITH THE UNIT.

CONDENSING UNITS



	Power supply
KSCM/ KSHM 22E	5 x 4 mm2
KSCM/ KSHM 26E	5 x 6 mm2
KSCM/ KSHM 32E	5 x 6 mm2
KSCM/ KSHM 38E	5 x 6 mm2
KSCM/ KSHM 43E	5 x 10 mm2
KSCM/ KSHM 52D	5 x 16 mm2
KSCM/ KSHM 64D	5 x 16 mm2
KSCM/ KSHM 76D	3 x 25 + 2 x 16 mm2
KSCM/ KSHM 86D	3 x 25 + 2 x 16 mm2
KSCM/ KSHM 112D	3 x 35 + 2 x 16 mm2
KSCM/ KSHM 128D	3 x 35 + 2 x 16 mm2
KSCM/ KSHM 152D	3 x 50 + 2 x 25 mm2
KSCM/ KSHM 214D	3 x 70 + 2 x 35 mm2
KSCM/ KSHM 76D KSCM/ KSHM 86D KSCM/ KSHM 112D KSCM/ KSHM 128D KSCM/ KSHM 152D	3 x 25 + 2 x 16 mm2 3 x 25 + 2 x 16 mm2 3 x 35 + 2 x 16 mm2 3 x 35 + 2 x 16 mm2 3 x 35 + 2 x 25 mm2

ELECTRICAL CONNECTION "REMOTE SIGNALS"



REMOTE ON/OFF: When contact is closed, unit is on.

COOL/HEAT: When contact is closed unit is running in cooling mode and when contact is openned unit is running in heating mode.

STAGE 1,2 3 and 4: Stage is activated when contact is closed.

	STAGE 1	STAGE 2	STAGE 3	STAGE 4
26E-43E	X			
52D-86D	X	X		
112D-152D	X	X	Х	
214D	Х	Х	Х	Х

1

REMOVE LINK FOR REMOTE ON/OFF OPERATION


COMPRESSOR SEQUENCE ACTIVATION

26E-43E



First step: Compressor 1


52D-86D



First step: Compressor 1 **Second step:** Compressor 3


Automatic sequence changeover

112D-152D



First step: Compressor 1
Second step: Compressor 2
Third step: Compressor 3

214D




First step: Compressor 1 Second step: Compressor 2 Third step: Compressor 3 Fourth step: Compressor 4

OPTIONS

1.- ARCHITECTURAL INTEGRATION


HIGH PRESSURE 125Pa FP1 (Only available for units 112D to 214D).

Units with high pressure fans. Available static pressure up to 125Pa.



HIGH PRESSURE 250Pa FP2 (Only available for units 112D to 214D).

Units with high pressure fans. Available static pressure up to 250Pa.



SQUARE DISCHARGE DUCT (FP1 and FP2 unit versions only).


It is formed by 1 or 2 square frames, for adapting discharge air from the unit to a square duct.

INLET PLENUM (FP1 and FP2 unit versions only). (Suppled loose).

It is a accessory for adapting the condenser air intake to accept a duct.

AUXILIARY DRIP TRAY (Only available for heat pump units with FP1/FP2 option).

Heat pump units can produce a large volume of water during the defrost cycle. You can use an auxiliary drip tray under the unit to collect all the defrost water and to assist with the removal to a suitable drain.



2.- SECURITY

MAIN SWITCH

The main switch is located on the access panel to the electrical box. It is equipped with a clutch gadget, which allows opening the panel of the electrical box, when it is on OFF position.

"SOFT STARTER" COMPRESSOR STARTING CURRENT CONSTRAINED.

It is an electronic element, which reduces the peak compressor starting current up to 40% (see pages of electrical data without soft starter).

RETURN LOCK THREE PHASES.

Located at electrical box of the unit. It assures that unit will not begin operation on detection of overvoltage, undervoltage, phase reversal fault or phase failure.

PROTECTION GRILL

The condenser coil protection grill prevents light damage to the coil when shipping and when installed.

3.- COMFORT, PRECISION AND ENERGY EFFICIENCY

LOW AMBIENT KIT 0° (COOLING UNITS ONLY, THE SERIES OF HEATING PUMP)

It is a crank case heater for the compressor which allows unit operation in cooling mode until 0°C of outdoor temperature. The purpose of the crank case heater is while the compressor is stopped, so that it can be properly lubricated when starts again.

LOW AMBIENT KIT -15°C (Only available for KSCM units).

It regulates the fan speed with a pressure transducer, in order to control condensing temperature. This option also includes a crankcase heater.

Thus the unit will be able to operate in the cooling cycles when the outdoor temperature is below 19°C (until -15°C). A solenoid valve has to be fitted by the installer in the liquid line (indoor unit) to prevent liquid return to the compressor. See electrical diagram supplied with the unit for the connection.

KIT LOW NOISE

Each compressor is fitted with a compressor acoustic jacket this provides attenuation of the compressor noise that radiates from the unit.

HOT GAS BY-PASS VALVE (Cooling only units).

Hot gas by-pass valve is an option that serves as extra stage of capacity control of the evaporator by injecting hot gas from high pressure side to the low pressure side after the expansion valve.

It can reduce the capacity of the unit between 40 and 80%.

HGBP valve has to be adjusted in the installation to regulate the capacity of the unit and taking into account evaporating in the compressor can not be below 2°C to prevent ice formming in the indoor coil.

The protection of indoor coil sensor is disabled by HGBP valve action.

RUBBER ANTI-VIBRATION MOUNTS

To install under the unit to avoid transmission of vibrations to the floor where unit is installed, while unit is operating. They are designed for low sensibility zones to vibration.

SPRING ANTI-VIBRATION MOUNTS (Only 112-152D units)

To install under the unit to avoid transmission of vibrations to the floor where unit is installed, while unit is operating. They are designed for medium and high sensibility zones to vibration.

4.- SERVICE

FACTORY PRECHARGED

This option includes service valves and R-410A refrigerant charged in outdoor unit (for 0 meters of connection lines).

SERVICE VALVES

As an option, the unit is fitted with gas and liquid service valves in order to make easier installation and maintenance operations.

- Valves for gas and liquid lines inside the units with welded connection for 22E to 214D.

DRIVE INDOOR FAN MOTOR OPTION

It includes the contactor and thermal switch, for indoor fan motor.

5.- COMUNICATION CAPABILITIES

MODBUS

It is possible to connect several units with a communication system (MOD BUS Protocol).

6.- EXTENDED LIFECYCLE

PRECOATED COIL

Special protection of the aluminum condenser coil fins, to protect it from aggressive external environmental conditions.

COMMISSIONING AND OPERATION

PRELIMINARY CHECKS BEFORE FIRST OPERATION

- Check that the **power supply** is the same as stated on the Rating Plate which is in agreement with the electrical diagram for the unit and that cable sizes are correct.
- Check that tightness of the electrical connections to their terminals and to ground.
- Check the control panel connections.

(If the connection is wrong, the unit will not operate and the control panel display will not light).

- Check with your hand that the fans turn freely.

FIGURE FOR THE STANDARD UNIT CONFIGURATION FOR MODELS: 52D-64D-76D-86D





CHECK COMPRESSOR OIL LEVEL

- Part of the compressor oil is pumped to the system when the compressor start, so for splits systems part of the oil can be placed in the system: piping lines, siphons, evaporator, etc.
- Oil quantity in the system depends on refrigerant charge. The compressor can not work either refrigerant defect nor with an excessive amount of this one.
- Depending on piping length, it can be necessary to add oil to the system.

In case of having to add oil, remember the type of oil is synthetic POE.

Original oil charge in the compressor is ICI Emkarate RL32-3MAF. This type of oil has to be used too in case of replacing the oil completely.

On the other hand to add oil RL32-3MAF or Mobil EAC Artic 22C can be used.

PRELIMINARY CHECKS AT FIRST OPERATION

To start the unit, **follow the instructions given in the User Manual for the control** supplied with the unit (requesting operation in any of the modes, cooling, heating, or automatic).

After a time lapse, the unit will start.

With unit operating, check that the fans are turning freely and in the proper direction.



COMPRESSOR SHOULD BE CHECKED THAT ROTATES IN THE CORRECT DIRECTION.

- If you have return return lock three phases as option check through it the correct rotation.
- If you do not have return lock three phases, check the correct direction of rotation. The pressure on the suction side decreases and the pressure on the discharge side increases when the compressor is activated.
- If the connection is wrong, the rotation will be reversed causing a a high noise level and a reduction in the amount of current consumed. If this occurs, the compressor's internal protection system will operate in shutting down the unit. The solution is to disconnect, switch the wires between two of the phases and connect the three again.

ASTP Protection is included with the unit compressors. See "Failure diagnosis" for more information.



WITH UNIT OPERATING, CHECK:

- Low pressure and high pressure.
- Evaporating and liquid temperature to calculate superheat and subcooling.
- Adjust according this values refrigerant charge and/or expansion valve in case it can be neccessary.



COMPRESSOR OIL LEVEL

Oil level has always to be checked. When the compressor stops the level should be between 1/4 and 3/4 in the sight glass, while during operation the level should be between 3/4 and full.

In case of having to add oil, remember the type of oil is synthetic POE.

Original oil charge in the compressor is ICI Emkarate RL32-3MAF. This type of oil has to be used too in case of replacing the oil completely.

On the other hand to add oil RL32-3MAF or Mobil EAC Artic 22C can be used.

MAINTENANCE

PREVENTIVE MAINTENANCE



PREVENTIVE MAINTENANCE PREVENTS COSTLY REPAIRS. BECAUSE OF THIS PERIODIC INSPECTIONS ARE REQUIRED:

- GENERAL STATE OF THE CASING:

Furniture, paint, deterioration due to bumps, rust spots, leveling and supporting, state of the shock absorbers, if installed, screwed panels, etc.

- ELECTRICAL CONNECTIONS:

State of hoses, tightness of screws, grounding, current draw of the compressor and fans and checking that the unit is receiving the correct voltage.

- COOLING CIRCUIT:

Check that pressure values are correct and that there are no leaks. Check that there is no damage to the pipe insulation, that the state of the coils is correct and that there are no chips or clogs retained by the air flow, etc.

- COMPRESSOR:

Inspect the oil level, if sight glass is present.

Inspect the state of the silent block fixtures.

- FANS:

Check that fans turn freely and in the correct direction without excessive noises.

- CONTROL:

Check Set Points and normal operation.

CORRECTIVE MAINTENANCE




IMPORTANT

MAKE SURE THAT THE UNIT IS COMPLETELY DISCONNECTED FROM THE POWER SUPPLY WHEN CARRYING OUT ANY TYPE OF WORK ON THE MACHINE.

If some component in the cooling circuit must be replaced, follow these recommendations:

- Always use original replacement parts.
- Remove the entire refrigerant charge from the unit through the schrader valves located in the outdoor section. Create a slight vacuum as a safety measure.
- Regulation prohibits the release on the refrigerant into the atmosphere.
- If cuts must be made in the pipe work, use pipe cutters. Do not use saws or any other tools that produce filings.
- All brazing must be carried out in a nitrogen atmosphere to prevent corrosion from forming.
- Use silver alloy brazing rod.
- Take special care that the flame from the torch is aimed in the opposite direction from the component to be welded and is covered with a wet rag in order to avoid overheating.



- Take very special care if 4-way check valves are to be replaced since these have internal components that are very heat-sensitive such as plastic, teflon, etc.
- If a compressor must be replaced, disconnect it electrically and un-braze the suction and discharge lines. Remove the securing screws and replace the old compressor with the new one. Check that the new compressor has the correct oil charge, screw it to the base and connect the lines and electrical connections.
- Carry out the vacuum above and below through the schrader valves of the outdoor unit until -750 mm Hg is reached. Once this level of vacuum has been reached, keep the pump in operation for at least one hour.

DO NOT USE THE COMPRESSOR AS A VACUUM PUMP.

- Charge the unit with refrigerant according to the data on the Rating Plate for the unit and check that there are no leaks.



PRECAUTIONS TO BE TAKEN IN THE USE OF R-410A Refrigerant:

R-410A Refrigerant is used in the unit: therefore, the following precautions characteristic of this gas should be taken:

- The Vacuum Pump must have a Check Valve or Solenoid Valve.
- Pressure Gauges and Hoses for the exclusive use with R-410A Refrigerant should be used.
- The charge should be carried out in the Liquid Phase.
- Always use scales to weight-in charge
- Use the Leak Detector exclusive for R-410A Refrigerant.
- Do not use mineral oil, only synthetic oil to ream, expand or make connections.
- Keep pipes wrapped before using them and be very thorough about any possible dirt (dust, filings, burrs, etc.).
- When there is a leak, gather what is left of the charge, create a vacuum in the unit and completely recharge with new R-410A Refrigerant.
- Brazing should always be carried out in a nitrogen atmosphere.
- Reamers should always be well sharpened.

MAINTENANCE

FAILURE DIAGNOSIS

In case of failure or malfunction of the unit, the display on the control panel will show an error or alarm warning explained in the control panel manual. Nevertheless, whenever there is a unit failure, the unit should be shut down and our service thecnicians consulted.

FAILURE	POSSIBLE CAUSES	POSSIBLE SOLUTIONS
	Failure in the power supply or insufficient voltage.	Connect the power supply or check the voltage.
UNIT DOES NOT START	Circuit breakers have opened.	Reset.
	Power cable or control panel cable is defective.	Inspect and correct.
	High pressure switch is defective.	Check cut-off pressure or change. Pressure switch if necessary.
UNIT STOPS DUE TO HIGH	Outdoor fan is not working.	Check for voltage, inspect the motor and turbine or replace if necessary
PRESSURE DURING THE	Outdoor fan turns in the wrong direction.	Switch the power phases.
COOLING CYCLE	Outdoor coil is dirty or clogged for passing air.	Inspect and clean.
	Excess charge of the refrigerant.	Remove the charge and charge according to the data on the rating plate.
UNIT STOPS DUE TO HIGH PRESSU- RE DURING THE HEATING CYCLE	The same causes and solutions as the cold cycle but	with reference to the coils and indoor fan.
	Low pressure switch defective.	Check the cut-off pressure with a pressure gauge and change the pressure switch if necessary.
	Indoor fan is not working.	Check for voltage and inspect the motor, turbine and replace if necessary.
UNIT STOPS DUE TO LOW	Indoor fan turns in the wrong direction.	Switch the power phases.
PRESSURE	Lack of refrigerant. Leak.	Correct leak, crate vacuum and charge.
	Dirty air filter.	Inspect and clean
	Clogged cooling circuit. Dirty filter drier.	Inspect and correct or change the filter drier.
	Compressor overcharged.	Inspect suction and discharge pressure values and correct.
UNIT STARTS AND STOPS IN SHORT CYCLES	Compressor cuts off due to Klixon.	Inspect input voltage and voltage drop.
	Lack of refrigerant.	Correct leak and replace.
LOAD AND ABNORMAL NOISE IN THE COMPRESSOR (SCROLL)	Power supply phases inverted (three-phase compressor).	Inspect and switch power phases.

SAFETY DEVICES

ASTP Protection:

This device protects the compressor against high discharge temperatures.

When the temperature reaches critical values, ASTP protection causes "Scrolls" are separated. Compressor may stop pumping with motor running.



- Occasionally, when compressor stops and starts, there is a metallic noise because of spirals of the compressor. This is normal.
- Connect high and low pressure gauges and check that operating pressure values are normal.
- Measure electrical consumption for the unit and check that it is near what is indicated on the specification plate.
- Check the electrical consumption of the compressor and the fans with what is specified in the physical data sheets.
- In the case of a Heat Pump unit, make a cycle change on the Control Panel checking that the 4-way valve makes the change correctly. Check the pressure values in the new cycle.
- Remember the low pressure switch is reset automatically and the high pressure switch is reset manually.
- Remember that low pressure switch is automatic reset, if it has 3 operations in one hour, it will be a manual reset, through the control of the unit.

MAINTENANCE

COOLING ONLY KSCM UNITS

22E to 43E							52D to 86D					112D to 214D											
	STD UNIT			COOLING LAK -15°C			STD UNIT		COOLING LAK-15°C			STD/FP1/FP2 UNIT		COOLING LAK -15°C		COOLING LAK -15°C (FP1/FP2)							
	Cycle	Set	Reset	Cycle	Set	Reset]	Cycle	Set	Reset	Cycle	Set	Reset		Cycle	Set	Reset	Cycle	Set	Reset	Cycle	Set	Reset
LP	cooling	3,5	4,5	cooling	3,5	4,5	LP1	cooling	3,5	4,5	cooling	3,5	4,5	LP1	cooling	3,5	4,5	cooling	3,5	4,5	cooling	3,5	4,5
							LP2	cooling	3,5	4,5	cooling	3,5	4,5	LP2	cooling	3,5	4,5	cooling	3,5	4,5	cooling	3,5	4,5
HP		43	34	cooling	43	34	HP1	cooling	43	34	cooling	43	34	HP1	cooling	43	34	cooling	43	34	cooling	43	34
							HP2	cooling	43	34	cooling	43	34	HP2	cooling	43	34	cooling	43	34	cooling	43	34
														HPR11	cooling	22	28	FSC1 (6A)		FSC1 (12A) (112÷152) FSC1 (20A) (214)			
														HPR12	cooling	37	30						
PT	T n/a		n/a (*)		PT1	1 n/a		(*)		PT1	n/a			(*)			(*)						
														HPR21	cooling	22	28	FSC2 (6A)					
														HPR22	cooling	37	30			FSC2 (12A) (112÷152) FSC2 (20A) (214)		. ,	
							PT2 n/a				(*)			PT2	T2 n/a			(*)			(*)		

Tables values in bar.


HEAT PUMP KSHM UNITS

	22E	to 43E		52D to 86D				112D to 214D				
	:	STD UNIT			:	STD UNIT			STD/FP1 / FP2 UNIT			
	Cycle	Set	Reset] [Cycle	Set	Reset		Cycle	Set	Reset	
LP	cooling	3,5	4,5	LP1	cooling	3,5	4,5	LP1	cooling	3,5	4,5	
				LP2	cooling	3,5	4,5	LP2	cooling	3,5	4,5	
HP	C/H	43	34	HP1	cooling	43	34	HP1	cooling	43	34	
				HP2	cooling	43	34	HP2	cooling	43	34	
								HPR12	cooling	37	30	
PT		(*)		PT1	(*)			PT1	(*)			
								HPR22	cooling	37	30	
				PT2	(*)			PT2	(*)			
								OT1	heating	6°C diff	erential 2,3	

Tables values in bar.

(*) REGULATION WITH CONTROL CLIMATIC 40

1.- FAN SPEED REGULATION KSCM+KIT -15°C AND KSHM 22E-86D



2.- DEFROST (PT/PT1/PT2)
- Start: 5,7 bars, during 60 seconds.

- End: 25 bars or passed 8 minutes, from the beginning of defrost.

1.- FAN SPEED REGULATION (PT1/PT2) KSHM STANDARD (with option FP1/FP2)

- Fan start-up 28 bar. 22 bar. - Cut off


2.- DEFROST (PT1/PT2)

5,7 bars, during 60 seconds. Start:

End: 25 bars or passed 8 minutes, from the beginning of

defrost.

3.- FAN SPEED REGULATION WITH PROPORTIONAL CONTROL (FSC1/FSC2)(PT1/PT2)



NOTES	
110.120	

NOTES	

NOTES	
NOTES	



www.lennoxeurope.com

BELGIUM, LUXEMBOURG

www.lennoxbelgium.com

CZECH REPUBLIC

www.lennox.cz

FRANCE

www.lennoxfrance.com

GERMANY

www.lennoxdeutschland.com

GREAT BRITAIN

www.lennoxuk.com

NETHERLANDS

www.lennoxnederland.com

POLAND

www.lennoxpolska.com

PORTUGAL

www.lennoxportugal.com

RUSSIA

www.lennoxrussia.com

SLOVAKIA

www.lennoxdistribution.com

SPAIN

www.lennoxspain.com

UKRAINE

www.lennoxrussia.com

OTHER COUNTRIES

www.lennoxdistribution.com

Due to Lennox's ongoing commitment to quality, the Specifications, Ratings and Dimensions are subject to change without notice and without incurring liability.

Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury.

Installation and service must be performed by a qualified installer and servicing agency.

((